

Declaration of Performance

According to Annex III of the Regulation (EU) Nr. 305/2011 (Construction Products Regulation).

Pacifyre® BFC Fire Collar

Nr. 2821-CPR-17-0285.

1. Unique identification code of the product-type:

- Pacifyre® BFC Fire Collar

2. Intended use of the construction product:

- Fire Stopping and Sealing Products for Penetration Seals, see ETA-17/0285

Pipe Penetrations

Plastic and Multilayer pipes

The field of application has to comply with the content of the ETA-17/0285

3. Name and contact address:

- J. van Walraven Holding B.V. - Industrieweg 5 - 3641 RK Mijdrecht - The Netherlands

4. System of assessment and verification of constancy of performance (AVCP) of the construction product:

- System 1

5. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

- Not applicable

6. European Assessment Document, European Technical Assessment, Technical Assessment Body & Notified Body:

EAD

ETA

TAB

NB

350454-00-1104

ETA-17/0285

ETA-Danmark A/S

UL International (NL) B.V., No. 2821

7. Declared performance:

Essential characteristics	Declared performance / Harmonised technical specification
Reaction to fire	Class E according EN 13501-1
Resistance to fire	In accordance with EN 13501-2. See annex
Dangerous substances	See annex
Durability and serviceability	Use category Type Y ₁
Other	Not applicable / No performance determined

8. The performance of the product identified in points 1 is in conformity with the declared performance in point 7.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

Signed for and on behalf of the manufacturer by:



Frank Nijdam

Group Director Product Marketing & Innovation

Mijdrecht, 25.04.2017

J. van Walraven Holding B.V